

Date of valid edition

2021-10-13

No./Revision:**4077-24****Date of first issue:**

2010-05-31

Name and address of certificate holder**Uponor Infra Oy
P.O. Box 21
FI-15561 NASTOLA**

Conformity marks covered by the certificate:

**Information regarding the certificate holder/manufactur**

Contact person Jaana Hallikas	Telephone +358 20 129 211	
	E-mail jaana.hallikas@uponor.com	
Manufacturer	Place of manufacture Fristad, Sverige	

Product covered by the certificate

Type of product	Standard/Normative document	Specific rules
Plaströrssystem för markförlagda självfallsledning för avloppsvatten strukturväggsrör. Omjukgjord polyvinylklorid (PVC-U), polypropen (PP) och polyeten (PE).	EN 13476	SBC 13476
Specification of product Lättviktsrör och rördelar av PP och PE enligt Bilaga 1. Godkända råmaterial enligt bilaga 2 (konfidentiell).		

The certificate holder above is hereby given permission to use the INSTA-CERT mark on or in connection with products, which fulfil the requirements of the standard or the normative document specified above (what is said in this document about INSTA-CERT mark will also be valid for marks defined in relevant SBC). The certificate is valid on the condition that the certificate holder complies with "General rules for certification by partners of INSTA-CERT" (GRC) and the specific rules applying to certification of products of the type mentioned. The certificate holder is obliged to indemnify INSTA-CERT partners of any claim for damages or any other expenses to which partners may become liable as a result of injuries caused by a product manufactured or sold by the certificate holder. This also applies to defective or faulty products.

Unless terminated, the certificate will be automatically extended for one year at a time. The certificate will be re-issued with a new "date of valid edition" only if the content and/or conditions of the certificate have been changed. Termination may take place to the end of a year subject to three months' notice on the part of the certificate holder and the certification body. Information of valid certificates is available on INSTA-CERT homepage, www.insta-cert.net.

The certificate is not transferable.

**MEMBER OF INSTA-CERT:
INSPECTA CERTIFIJOINTI OY**

Maija Vanttaja, Managing Director

Certificate No. **4077-24**

Date 2021-10-13

Certificate holder

Uponor Infra Oy
P.O. Box 21
FI-15561 NASTOLA

GODKÄNDA PRODUKTER

UPONOR markavloppssystem					
Produktnamn	UPONOR IQ-rör	UPONOR Ultra Double	Ultra Rib 2 och Ultra Rib 2 Blue	Ultra Classic - rör	Uponor Weholite PE - rör
Material	PP	PP	PP	PP	PE
Färg					svart
- yttre sida	svart	brun	rödbrun	brun eller svart	
- inre yta	grå och vit	grå och vit	grå	brun, grå eller vit	
Standard dimension	B	B	B	A1	A2
Ringstyvhet	SN 8	SN 8	SN 8	SN4 och SN8	SN4 och SN8
Användningsområde	UD				
- Dimensioner/OD, mm (- storleksgrupper 1 och 2)	200, 250 och 315	200, 250 och 315	110 - 315	110 och 160	
- Dimensioner/ID; mm (- storleksgrupper 1 och 2)	200 och 300				
Användningsområde	U				
- Dimensioner/OD, mm (- storleksgrupper 2 och 3)		450 och 560	400 - 1200		
Dimensioner/ID, mm (- storleksgrupper 2 och 3)	400, 500, 600 och 800				400 -1000
Dimensioner/ID, mm (- storleksgrupp 3)		600			
Rör utan muff Dimensioner/ID, mm (- storleksgrupp 3)					1200
Tillverkarens beteckning på produkter	5				